

**REQUIRED ICE BARRIER**

**R905.2.7.1 Ice Barrier.** In areas where there has been a history of ice forming along the eaves, causing a backup of water as designated in Table R301.2(1), an ice barrier that consists of at least two layers of underlayment cemented together or a self-adhering polymer modified bitumen sheet, shall be used in lieu of normal underlayment and extend from the lowest edges of all roof surfaces to a point at least 24 inches (610 mm) inside the exterior wall line of the building.

Village of Winnebago  
Building & Zoning Department